

HIMACHAL PRADESH
PUBLIC WORKS DEPARTMENT

No.PW/KD/CB/WA/Building Safety/2022/- 2788-89 Dated: - 26-5-22
To


✓
The Principal,
Vihaan Valley School
Tiara Distt.Kangra (HP)

Subject: - School building safety certificate.

Reference: - Your application No. VVS/BSC/2022/05 dated 07.03.2022.

As desired vide your letter under reference, the School building safety certificate as received from the Assistant Engineer, HPPWD, Sub Division, Lunj vide his office letter No. 156 dated 10.05.2022 is sent herewith for information.

Encl/ As above.


Executive Engineer
Kangra Division,
HP: PWD, Kangra.

Copy to the Assistant Engineer, HP.PWD, Sub Division Lunj for
information w.r. to above.
Encl/ Nil.

Executive Engineer
Kangra Division,
HP: PWD, Kangra



VIHAAN EDUCATION SOCIETY
TIARA (H.P.)
President

SAFETY CERTIFICATE

The School building of Vihaan Valley School Tiara Tehsil & Distt. Kangra was inspected by the Junior Engineer (Tiara Section) on dated 5.05.2022. As per the report of the Junior Engineer, this building has neither been designed nor been supervised by this department and no earthquake resistant provisions have been adopted for the design of this building & no structural drawings duly approved by the competent Govt. certified Engineer were produced at the time of inspection. So this structure is a non-engineered structure. Hence, the structural safety of this building cannot be ensured specifically from the earthquake resistant point of view. This department will not be responsible for any type of loss of life and property etc., if this structure fails under any circumstances. The CCTV Cameras have been installed in the building. However, as per the visual inspection of the building this time it has been found safe. No Officer/Official of this office will plead in any Hon'ble court of law in case of dispute. As per certificate issued by Pardhan Gram Panchayat Tiara dated 18.04.2022 this building was constructed in the year 2011. As per the direction issued by Additioanl Chief Secretary (PW) to the Govt. of HP Shimla Letter No.PBW (B) E(3) 95/2019 dated 5.05.2021 for age of 0-15 years, safety certificate is to be issued for Five years. Hence it is valid till 31.03.2027.

Note: This certificate is valid upto the year 2026-27 or till any addition or substantial change in loading of the building structure is made.

Assistant Engineer,
HP PWD Sub-Division,
Lunj.

Executive Engineer,
Kangra Division,
HP. PWD, Kangra



VIHAAN EDUCATION SOCIETY
TIARA (H.P.)
President